



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	5278-2142:0503
<b>CATEGORY:</b>	5278 - CARBON MONOXIDE DETECTORS
<b>LISTEE:</b>	QOLSYS 1919 S. Bascom Ave, Ste. 600, Campbell, CA, 95008 Contact: Nita, Dan 416-357-1409 Email: dan.nita@jci.com
<b>DESIGN:</b>	Model QS5210-840 wireless, battery operated, carbon monoxide detector with 3 VDC lithium battery and radio frequency transmitter.  Refer to listee's installation, operation, and maintenance manual, manufacturer's product data sheets for additional detailed product description and operational considerations.
<b>RATING:</b>	3VDC lithium battery, type CR123A, manufactured by Panasonic.
<b>INSTALLATION:</b>	In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, electrical rating and UL label.
<b>APPROVAL:</b>	Listed as a residential, single station carbon monoxide detector for use with the UL 985 Listed control panel, Qolsys Model IQPanel2.  Refer to Manufacturers Installation, Operation, and Instruction Manual for details.
<b>NOTES:</b>	

04-11-2019 dcc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 08/23/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division